

**ADDENDUM 001  
REQUEST FOR BIDS  
RFQ NUMBER: D9080596RY**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original proposal. The due date for receipt of quote remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Gloria Perkins Procurement Supervisor
Contractor/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Gloria Perkins</i>  (Authorizing Signature)
Date Signed:	Date Signed: 10-9-07

Question: A profile specification was not given. Will one be required?

Response: The grooving is for friction on existing asphalt only. A profile specification is not necessary.

Question: May millings be disbursed on the right-of-way?

Response: There shouldn't be many millings so it will be permissible to disburse on right-of-way.